Fluoride in New Jersey Public Water Supplies January 2011

All ground and surface water in the United States, including in New Jersey, contains naturally occurring fluoride; some water systems add fluoride to the water. Tooth enamel of a child's developing primary and permanent teeth will be permanently strengthened, and tooth decay prevented, by absorbing fluorides from the blood. These can come from natural or added fluoride in drinking water, food or toothpaste, among other sources.

The fluoride level the U.S. Centers for Disease Control (CDC) recommend to prevent tooth decay is 0.7 parts of fluoride per million parts (ppm) of water, and not more than 2.0 ppm to avoid mild fluorisis (slight mottling of tooth enamel). If a water supply has less than that amount naturally, adding fluoride to bring levels to the recommended level results in "fluoride-adjusted" water supplies; this term does not include supplies with only natural fluoride (including private well water).

The next pages list water suppliers that add fluoride, and water supplies whose natural levels of fluoride meet or approach CDC-recommended levels to prevent tooth decay.

For more information on this topic, contact:

New Jersey Dental Association One Dental Plaza North Brunswick, NJ 08902 732-821-9400 www.njda.org

New Jersey Department of Health and Senior Services School and Oral Health PO Box 364 Trenton, NJ 08625-0364 609-943-5749 http://www.state.nj.us/health/fhs/newborn/oralhealth.shtml

National Fluoridation Engineer Centers for Disease Control and Prevention 770-488-6076 http://www.cdc.gov/fluoridation/

New Jersey Department of Environmental Protection Bureau of Safe Drinking Water Technical Assistance PO Box 426 Trenton, NJ 08625-0426 609-292-5550 http://www.nj.gov/dep/watersupply/safedrnk.htm

New Jersey Fluoride-Adjusted Public Water Supplies

These data are the most accurate the state has, but they can change as water systems change in size (for example, larger systems buy smaller ones) and fluoridation (by season or location within a community; systems may stop or start fluoridation, or buy fluoridated water from other systems). Check with your water system for the most up-to-date information about fluoride-adjusted water presence and levels delivered to your area.

County	Water System	Communities Served by Fluoride-		
Atlantic	Atlantic City WD	Adjusted Water [FAW] (part or all) Atlantic City		
Attailtic	Egg Harbor City WD	Egg Harbor		
	McGuire Air Force Base	North Hanover		
	Willingboro MUA			
	Mt. Laurel Twp MUA	Willingboro Mt. Laurel		
Burlington	U.S. Army Fort Dix	North Hanover		
Durinigton	•	Chesterfield		
	Aqua New Jersey—Hamilton Square	Chesterneid		
Gloucester	Washington Township MUA	Washington		
Hunterdon	New Jersey American-Raritan	FAW direct from NJA-R year-round:		
		Readington, Three Bridges, Whitehouse,		
		Whitehouse Station		
		FAW direct from NJA-R only if town		
		needs emergency water:		
		Flemington		
	East Windsor MUA	East Windsor		
	Aqua New Jersey—Hamilton	Hamilton; Robbinsville		
Mercer	Square	III abtatavin		
Mercer	Hightstown WD Trenton Water Works	Hightstown		
	Trenton water works	Ewing; Hamilton; Hopewell Twp; Lawrence; Trenton		
	New Jersey American-Raritan	Hightstown; Hopewell Twp; Lawrence;		
	, and the second	Princeton Boro; Princeton Twp; West		
		Windsor		
	South Brunswick Twp WD	South Brunswick		
Middlesex	New Jersey American-Raritan	Cranbury; Jamesburg; Kingston;		
	(directly or via NJA-Jamesburg)	Plainsboro (parts)		
Monmouth	Allentown WD	Allentown		
	Freehold Borough WD	Freehold Boro; Freehold Twp		
	Freehold Township WD	Colts Neck; Freehold Township		
	S B Water	Colts Neck		

County	Water System	Communities Served by Fluoride-		
		Adjusted Water [FAW] (part or all)		
		FAW direct from NJA-CN year-round:		
M	NI I Ai	Aberdeen; Allenhurst; Asbury Park; Bay		
Monmouth	New Jersey American—	Head; Bradley Beach; Brick Twp (part);		
(cont'd)	Coastal North	Colts Neck (part); Deal; Dover Township		
		(part); Eatontown; Elberon; Fair Haven;		
		Highlands Borough; Holmdel;		
		Interlaken; Lavalette (part); Little Silver;		
		Loch Arbor; Long Branch; Mantoloking;		
		Middletown; Monmouth Beach;		
		Neptune; Neptune City; Ocean Twp;		
		Ocean Grove; Oceanport; Red Bank		
		(part); Rumson; Sea Bright; Shrewsbury		
		Borough; Shrewsbury Twp; Tinton Falls;		
		Wanamassa; West Long Branch		
		FAW direct from NJA-CN Dec-Feb:		
		Howell Twp (eastern, southern);		
		Lakewood (northern)		
		FAW bought from NJA-CN by other		
		systems year-round:		
		Lake Como; Point Pleasant Borough;		
		Shorelands Water Company		
		FAW bought from NJA-CN by other		
		systems year-round for part of year:		
		(Sept-May) Avon by the Sea; Belmar;		
		Matawan; (Sept-April) Union Beach via		
		Shorelands Water Co. (Oct-May) East		
		Keansburg; (Dec-June) Red Bank (part);		
3.6 .	N. I. A D	(Dec-Feb) Farmingdale Borough		
Morris	New Jersey AmericanRaritan	FAW direct from NJA-R year-round:		
<u> </u>	N. I. A. '. D.'	Chester		
Somerset	New Jersey AmericanRaritan	FAW direct from NJA-R year-round: Belle Mead; Branchburg; Bridgewater		
		(only Bradley Gardens, Finderne, Green		
		Knoll); Flagtown; Gladstone;		
		Hillsborough; Manville; Millstone Twp (part); Montgomery (includes Skillman);		
		Neshanic Station; Peapack; Pottersville; Raritan Boro; Somerville; Tewksbury		
		FAW bought from NJA-R by other		
		systems year-round:		
		Bedminster (NJA-Short Hill)		
Sussex	Newton Water & Sewer	Newton		
Subbox	Authority			
Union	United Water Rahway	Rahway		
	cipal Utilities Authority: WD- Water			

MUA= Municipal Utilities Authority; WD= Water Department. Communities named may be served as well by other systems that do not fluoridate.

New Jersey Natural-Fluoride Public Water Supplies at or near Desired Concentrations

January 2011

The maximum naturally occurring fluoride permitted in drinking water is 4 parts per million (ppm), versus 2 ppm recommended for fluoride-adjusted water. The Centers for Disease Control have recommended an optimal concentration nationwide of 0.7 ppm, versus an earlier range of 0.8-1.5 ppm in New Jersey. Water systems were listed below if they had at least one sample of at least 0.7 ppm of fluoride between January 1, 2008 and January 1, 2011. Note that this level of fluoride may not be consistent across time.

Camden Cumberland	Buena Borough Aqua NJ-Blackwood Bayshore Mobile Home Park Clayton WD Deptford Twp MUA	Served (part or all) Buena Blackwood Stow Creek Clayton	Range (parts per million) 0.47-0.79 nd-0.77 1.31	1-2-08 to 1-6-10 2008-10 various 1-15-09
Camden Cumberland	Aqua NJ-Blackwood Bayshore Mobile Home Park Clayton WD	Buena Blackwood Stow Creek	0.47-0.79 nd-0.77	2008-10 various
Camden Cumberland	Aqua NJ-Blackwood Bayshore Mobile Home Park Clayton WD	Blackwood Stow Creek	nd-0.77	2008-10 various
Cumberland]	Bayshore Mobile Home Park Clayton WD	Stow Creek		
]	Park Clayton WD		1.31	1-15-09
(]	Clayton WD	Clayton		
]	•	LLIANTON	0.454.1.76	7 (14 22 20) 00
	Denttord Lwn MILLA	·	0.454-1.76	7-(14,23,29)-09
]		Deptford	nd-1.28	12-15-10
	Glassboro WD	Glassboro	nd-1.84	6-24-08; 4-28-09
	Mantua Twp MUA	Mantua	0.11-1.78	5-27-08
	Manor Water Assns	Mantua	1.22-1.23	4-24-09
	Monroe Twp MUA	Monroe Twp	nd-0.756	2008-2010 various
	New Jersey American-	Harrison	0.4-1.23	4-10-08, 4-29-09,
<u> </u>	Harrison			6-4-09
]	Pitman WD	Glassboro, Mantua, Pitman	1.83-2.3	6-23-09
7	Wenonah WD	Wenonah	1.36-1.38	6-4-09
	West Deptford Twp WD	West Deptford Twp	0.62-1.47	5-19-08
	Woodbury City WD	Woodbury	0.2-1.37	2-28-08 to 5-15- 08
Mercer	Pennington WD	Pennington	0.6-0.8	9-24-09
	AWM Four Seasons at	Chester	1.02-1.03	1-6-09
	Chester	Chester	1.02-1.03	1-0-09
<u> </u>	Cliffside Park Water Assn	Cliffside Park	nd-1.2	8-11-08, 8-12-08, 11-23-09
	West Milford Twp MUA Awosting	West Milford	nd-0.9	7-29-09
	West Milford Twp MUA Olde Milford Estate	West Milford	nd-2.0	7-27-09
]	Elmer Boro WD	Elmer	0.71-0.79	8-2-09
Salem	Woodstown WD	Mannington,	0.282-2.82	5-5-09
		Pilesgrove,		
		Woodstown		
Sussex	Great Gorge Terrace Assn	Vernon	1.44-1.49	8-12-09
	Valley View Apartments		0.69-2.18	12-24-09

MUA= Municipal Utilities Authority; WD= Water Department. nd=not detectable